


SIDE VIEW



TOP VIEW

DOUBLE CHECK OR BACKFLOW PREVENTER

3/4" & 1"

NOT TO SCALE

NOTES:

1. MIN. WIDTH OF BOX 6' INSIDE.
2. POURED CONCRETE OR PRECAST CONCRETE BOX, KNOCK-OUT TYPE IS NOT ACCEPTABLE
3. WHERE A POSITIVE DRAIN (NO SURCHARGING) IS AVAILABLE, A FLOOR DRAIN WITH A 2" SLOPED CONCRETE BOTTOM MAY BE USED AND THE VAULT CAN BE INSTALLED WITH THE TOP 2" ABOVE GRADE.
4. IF SUBJECT TO TRAFFIC PROVIDE A HEAVIER DOOR.
5. IF PIPING ENTERS THROUGH SIDE OF BOX, PROVIDE A UNIFLANGE COUPLING AT THE VALVE CONNECTION.
6. REFER TO THE WATER DISTRIBUTION SYSTEM SPECIFICATIONS FOR ALL ACCEPTABLE MANUFACTURERS.

HILTON HEAD NO. 1 PUBLIC SERVICE DISTRICT

DOUBLE CHECK OR BACKFLOW PREVENTER 3" AND LARGER

APPROVED BY:	DATE:	DRAWING NO.
LC	Feb. 1997	VIII-10
SCALE:	REVISED:	
NTS	Jan. 2024	