



NOTES:

1. THE CLEANOUT SHOULD BE THE SAME SIZE DIAMETER AS THE LINE THAT IT IS INSTALLED ON.
2. CLEANOUT SHOULD CONSIST OF A PLUG SUITABLE FOR AIR TEST.
3. ONLY GLUE FITTINGS ARE TO BE USED.
4. REFER TO THE GRAVITY SEWER SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS.

CLEANOUT DETAIL

NOT TO SCALE

HILTON HEAD NO. 1
PUBLIC SERVICE DISTRICT

CLEANOUT DETAIL

APPROVED BY:

LC

DATE:

Jul. 2000

DRAWING NO.

SCALE:

NTS

REVISED:

Jan. 2024

XII-13