



NOTES:

1. REFER TO THE TOWN OF HILTON HEAD FOR OFF-SITE IMPROVEMENTS REQUIRED FOR PUMP STATIONS INCLUDING LANDSCAPING, SIDEWALK, SETBACKS, BUFFER REQUIREMENTS, ETC.
2. PIPE ABOVE GROUND IS 401 COATED, GREEN PAINTED DUCTILE IRON PIPE.
3. REFER TO THE SPECIFICATIONS FOR GREASE TRAP REQUIREMENTS. DHEC REG. 61-56.201.2.
4. SWING CHECK VALVES SHOULD BE UTILIZED.
5. FULL RADIO TELEMETRY IS REQUIRED AT ALL NEW PUMP STATIONS.
6. REFER TO THE SANITARY SEWER PUMP STATION SPECIFICATIONS FOR ACCEPTABLE MANUFACTURERS.

HILTON HEAD NO. 1
PUBLIC SERVICE DISTRICT

TYPICAL PLAN VIEW
SUBMERSIBLE PUMP STATION

APPROVED BY:	DATE:	DRAWING NO.
XXXXXXX	Sep. 2002	
SCALE:	REVISED:	XX-6
NTS	Jan. 2024	